



CERTIFICATE FI/40127

Our Ref. HEL-CERT190300212-01

Product PVC-sheathed wiring cable

Type MMJ
MMJK

Trade mark KAJOTE

Certificate Holder Kajote Oy
Orvokintie 9
FI-06100, Porvoo, Finland

Technical information Numeral and nominal cross-sectional area of conductors:
MMJ 2-5 x 1,5-2,5 mm²
MMJ 2-5 x 6-25 mm²
MMJK 2-5 x 1,5-16 mm²

Other information MMJ 2-5 x 1,5-2,5 mm², rated voltage 300/500 V
MMJ 2-5 x 6-25 mm², rated voltage 450/750 V
MMJK 2-5 x 1,5-16 mm², rated voltage 450/750 V

The product is certified according to the following standard(s) SFS 2091:2011
EN 50525-1:2011

Validity This certificate is valid until 26 March 2024 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Date of issue 26 March 2019

SGS Fimko Ltd

Signature

Sixten Lökfors
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: FI/40127

Manufacturer

Kajote Oy
Orvokintie 9
FI-06100, Porvoo, Finland

Manufacturing site(s)

Kajote Oy
Orvokintie 9
FI-06100, Porvoo, Finland

Additional information

This certificate replaces Certificate FI 28498 dated 26 March 2014, due to removed type MKMJ and new testing.



MMJK:
Self-supporting MMJ cable with parallell covered longitudinal carrier cable (support cable).
Breaking load of support cable 11 kN.

As shown in the Test Report(s) No(s): 294722-2

This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.