



SGS

CERTIFICATE FI/41214

Our Ref. HEL-CERT211001106-01



Product PVC sheathed special cable

Type MPK (07VV-K)

Trademark KAJOTE

Certificate Holder Kajote Oy
Orvokintie 9
FI-06100, Porvoo, Finland

Technical information Number and nominal cross-sectional area of conductors:
2-5 x 1,5-2,5 mm²

Other information Cable for pole luminaire
Rated voltage 450/750 V

The product is certified according to the following standard(s) EN 50525-2-31:2011
SFS 2091:2011

Validity This certificate is valid until 2026-10-06 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2021-10-06

SGS Fimko Ltd

Signature



Sixten Lökfors
Project Manager

Page 1 of 2

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



SGS Fimko Ltd

Takomotie 8, FI-00380 Helsinki, Finland
t. +358 9 696 361 www.sgs.fi

Business ID 0978538-5

Member of the SGS Group (SGS SA)

Manufacturer Kajote Oy
Orvokintie 9
FI-06100, Porvoo, Finland

Manufacturing site Kajote Oy
Orvokintie 9
FI-06100, Porvoo, Finland

Directive information The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Additional information Installation cable for special purpose inside luminaire poles
Insulation tested according to EN 5025-2-31
Sheath tested according to Finnish National Standard SFS 2091
The insulation and sheath withstands the bending test in low temperature -25 °C

This certificate replaces Certificate FI 29600 dated 28 June 2016, due to new testing.

Based on: HELES2106000616-1 and 282970-1