

CERTIFICATE FI/42359

Our Ref. HEL-CERT190400240-03



Product PVC-insulated heat resistant single-core cable

Type H07V2-K
07V2-K

Trademark KAJOTE

Certificate Holder Kajote Oy
Orvokintie 9, FI-06100, Porvoo, Finland

Technical information H07V2-K 1,5-35 mm² (MKEM 90)
07V2-K 50-240 mm² (MKEM 90)
Rated voltage: 450/750 V

Other information

The product is certified according to the following standard(s) EN 50525-1:2011 + A1:2022
EN 50525-2-31:2011

Validity This certificate is valid until 21 October 2030 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 21 October 2025

SGS Fimko Oy


Signature



Certificate issued by

SGS Fimko Oy
Takomotie 8
FI-00380 Helsinki, Finland
t. +358 9 696 361 www.sgs.com
Business ID 0634247-4

Member of the SGS Group (SGS SA)



Manufacturer	Kajote Oy Orvokintie 9, FI-06100, Porvoo, Finland
Manufacturing site	Kajote Oy Orvokintie 9, FI-06100, Porvoo, Finland
Directive information	The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.
Additional information	Types 07V2-K are non-harmonized cables due to cross-sectional area being greater than what is set for harmonized type H07V2-K (max 35 mm ²). Wires of plain (MKEM 90) or tinned (MKEMT 90) copper.
As shown in the Test Report(s) No(s):	HELES2411001026-1, HELES2411001026-2